

MSD HAZARDOUS MATERIALS ORDINANCE RELATED INCIDENTS
April 2026 RGM

DATE	INCIDENT ID	INCIDENT COMMAND	RESPONSIBLE PARTY	LOCATION	ROOT CAUSE AND/OR FINDINGS	MATERIAL	HAZMAT LEVEL	MITIGATION/REMEDATION EFFORTS	ENFORCEMENT ACTION	CORRECTIVE ACTIONS & PREVENTION
3/16/2026	26ER1046	ANC-MID FD	MVA	Intersection of I 71 SOUTH and I 264 RAMP	Approximately 100 gallons of diesel fuel released due to MVA	Diesel Fuel	1	FD placed powder absorbent. LMPHW responsible for cleanup efforts. Cleanup orders issued.	NFAN	N/A
3/18/2026	26ER1047	PRP FD	Zeon	4100 BELLS LN LOUISVILLE KY	Approximately 4 gallons of diesel fuel released due to pump flow valve failure. Sanitary system impacted.	Diesel Fuel	0	Absorbent booms applied. Industry responsible for remediation efforts.	NFAN	Contractor developed SOPs for fueling. Pump lock mechanism removed.
3/19/2026	26ER1048	LOU FD	UPS	911 GRADE LN LOUISVILLE KY	Approximately 20 gallons of Jet Fuel released due to sump pump malfunction. Material contained to an Oil Water Separator.	jet fuel	0	Industry responsible for remediation efforts.	NFAN	Repairs made and inspections will continue to be performed.
3/18/2026	26ER1049	JTWN FD	Key Oil	10921 PLANTSIDE DR JEFFERSONTOWN KY	Approximately 20 gallons of diesel fuel released due to unattended pump.	Diesel Fuel	1	FD applied powdered mitigant. LMPHW responsible for remediation efforts.	NFAN	No responsible party identified
3/20/2026	26ER1050	N/A	U of L	2315 S FIRST STREET WALK LOUISVILLE KY	Approximately 40 gallons of ethylene glycol released due to generator malfunction. Material impacted CSS.	Ethylene Glycol	0	Facility collected and disposed of remaining material.	NOV (HMO 95.06)	Facility and contractor service provider to perform routing visual inspections. Facility may possibility change over to less hazardous material.
3/22/2026	26ER1051	ANC-MID FD / OKOLFD / JTWNFD	Retirement Homes	901 BLANKENBAKER PKY MIDDLETOWN KY	Unknown amount of firewater released into Chenoweth Run resulting from structure fire.	Fire Water	0	Absorbent booms placed downstream by MSD.	NFAN	N/A; Firefighting operations
3/20/2026	26ER1052	N/A	XPO Logistics	6300 GEIL LN LOUISVILLE KY	Approximately 30 gallons of diesel fuel released resulting from leak in line from master dispenser to satellite dispenser. Stormwater system impacted.	Diesel Fuel	0	PECCO provided cleanup. KYERT over remediation efforts.	NOV (HMO 95.06 & WDR 5.04)	Facility reviewing testing data and will update equipment.
3/31/2026	26ER1055	LOU FD	SEight Offroad & Fab	1193 BRIDEN AVE LOUISVILLE KY	Approximately 5 gallons of urethane released due to spill.	Urethane	0	LMPHW responsible for remediation efforts. Material contained and disposed of by industry.	NFAN	No PRR Issued; non-RQ
3/31/2026	26ER1056	PRP FD	Eckart	4101 CAMP GROUND RD LOUISVILLE KY	Approximately 15 gallons of mineral spirits released into environment due to gasket failure. Stormwater conveyance affected.	Mineral Spirits	1	Industry and FD applied absorbent pads and booms.	NOV (WDR 5.04)	Industry to replace paper gaskets with reinforced gaskets
3/31/2026	26ER1057	LOU FD	Atlantic Aviation	1131 STANDIFORD AVE LOUISVILLE KY	Approximately 250 gallons of jet fuel released due to MVA involving fuel truck.	Jet Fuel	1	LMPHW responsible for cleanup efforts. PECCO remediated site.	NFAN	N/A; MVA

ABBREVIATIONS

ANC-MID FD	ANCHORAGE/MIDDLETOWN FIRE DEPARTMENTS
APCD	AIR POLLUTION CONDTRDOL DISTRICT
CSS	COMBINED SEWER SYSTEM
EMA	EMERGENCY MANAGEMENT AGENCY
FC FD	FERN CREEK FIRE DEPARTMENT
FCN	FIELD CORRECTION NOTICE
FD	FIRE DEPARTMENT
FRDLFD	FAIRDALE FIRE DEPARTMENT
FF	FIRE FIGHTING
HMO	HAZARDOUS MATERIALS INCIDENT
IBC	INTERMEDIATE BULK CONTAINERS
IWD	INDUSTRIAL WASTE DEPARTMENT
J-TOWN FD	JEFFERSONTOWN FIRE DEPARTMENT
KYDOW	KENTUCKY DIVISION OF WATER
KYERB	KENTUCKY EMERGENCY RESPONSE BRANCH
KYERT	KENTUCKY EMERGENCY RESPONSE TEAM
LMPHW	LOUISVILLE METRO DEPARTMENT OF HEALTH & WELLNESS
LOU FD	LOUISVILLE FIRE DEPARTMENT
MSD	LOUISVILLE METROPOLITAN SEWER DISTRICT
MS4	MUNICIPAL SEPARATE STORM SEWER SYSTEM
MVA	MOTOR VEHICLE ACCIDENT
N/A	NOT APPLICABLE
NFAN	NO FURTHER ACTION NEEDED
NOV	NOTICE OF VIOLATION
OKOFD	OKOLONA FIRE DEPARTMENT
RQ	REPORTABLE QUANTITY
PRP FD	PLEASURE RIDGE FIRE DEPARTMENT
PRR	PRELIMINARY RESPONSE REPORT
RAAFR	REG Airport Auth/Air/Fire/Rescue
RGM	RESPONSE GROUP MEETING
STMA FD	ST. MATTHEWS FIRED DEPARTMENT

Cases are released after investigation is completed and reviewed in monthly Response Group Meetings (RGM) involving MSD, EMA, LMPHW, and APCD.
Cases related to hazardous materials, including declared hazmat levels by fire departments, are listed but may not meet the definition of a hazardous materials incident per the HMO.